

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

April 29, 2014

WATER CONTROL CORPORATION BRIAN SODERHOLM 7150 143RD AV. NW RAMSEY MN 55303

Re: Description: WATER TREATMENT DEVICE - SOFTENER/CATION EXCHANGE

Manufacturer: WATER CONTROL CORPORATION

Product Name: POLYCLEAR SERIES

Model Number(s): WNY24, WNYT24, WNY24T, WNYT24T, WNY32, WNY32T, WNYT32T, WNYT32T,

WNYT48, WNYT48T, WNYT60 AND WNYT60T (POE)

Product File No: 20140120

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2019.

This approval supersedes the approval issued on May 21, 2009 under product file number 20090134.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those
 contaminants and/or substances as specified in this approval letter when the product is installed and maintained
 in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If these approved devices are modified or additional assertions of function or performance are made, then this
 approval shall be considered null and void, unless the change is submitted to the department for review and the
 approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

SBD-10564-E (N.10/97) File Ref: 14012002.DOC

Water Control Corporation April 29, 2014 Page 2 of 2

Product File No.: 20140120

WATER SOFTENING CAPABILITIES PRODUCT FILE NUMBER 20140120 TABLE 1 OF 1

| Model Numbers | | Capacities* | | | | | | Flow Rates vs. |
|-------------------|------------|-------------|--------|----------|--------|----------|--------|-----------------|
| Flo Master Series | | Rating 1 | | Rating 2 | | Rating 3 | | Pressure Losses |
| Metered | Time Clock | Grains | Pounds | Grains | Pounds | Grains | Pounds | gpm @ psig |
| WNY24 | WNY24T | 9,300 | 2.3 | 15,300 | 4.5 | 17,600 | 6.8 | 8.5 @14 |
| WNYT24 | WNYT24T | 9,300 | 2.3 | 15,300 | 4.5 | 17,600 | 6.8 | 8.5 @14 |
| WNY32 | WNY32T | 13,300 | 3.0 | 21,800 | 6.0 | 25,100 | 9.0 | 9.5 @ 14 |
| WNYT32 | WNYT32T | 13,300 | 3.0 | 21,800 | 6.0 | 25,100 | 9.0 | 9.5 @ 14 |
| WNYT48 | WNYT48T | 19,900 | 4.5 | 32,700 | 9.0 | 37,600 | 13.5 | 10.3 @ 15 |
| WNYT60 | WNYT60T | 26,500 | 6.0 | 43,600 | 12.0 | 50,100 | 18.0 | 11.7 @ 15 |

^{*} The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 were conducted in accordance with WQA Standard S-100.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail